

# Assessment of the indoor/outdoor dynamic of some air pollutants in three buildings located in the valley city of Chambéry, France

Diana Decilap, Gaëlle Guyot, Jean-Luc Besombes, Benjamin Golly

# ▶ To cite this version:

Diana Decilap, Gaëlle Guyot, Jean-Luc Besombes, Benjamin Golly. Assessment of the indoor/outdoor dynamic of some air pollutants in three buildings located in the valley city of Chambéry, France. 44th AIVC -12th TightVent & 10th venticool Conference, AIVC, Oct 2024, Dublin, Ireland. hal-04786337

# HAL Id: hal-04786337 https://cnrs.hal.science/hal-04786337v1

Submitted on 15 Nov 2024

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# Assessment of the indoor/outdoor dynamic of some air pollutants in three buildings located in the valley city of Chambéry, France

Diana Decilap\*1, 2, Gaëlle Guyot2, Jean-Luc Besombes3, and Benjamin Golly1

1 Univ. Savoie Mont Blanc, CNRS, LOCIE 73000 Chambéry, France \*Corresponding author: diana.decilap@developpement-durable.gouv.fr Presenting author

2 Cerema, BPE research team 46 rue St Théobald 38081 L'Isle d'Abeau, France

3 Univ. Savoie Mont Blanc, CNRS, EDYTEM 73000 Chambéry, France

#### **KEYWORDS**

Air pollution, I/O ratio, PM2.5, NO2, building ventilation system

#### 1 INTRODUCTION

In recent years, population exposure to air pollution has been a major concern. Indoor air quality (IAQ) is mainly monitored with CO<sub>2</sub>-concentration-based indicators. High levels of CO<sub>2</sub>-concentration are avoided in buildings when airing by the windows is done and/or when air exchange rate of the existing ventilation is regulated, based on a CO<sub>2</sub>-level-information. However, as contributing to maintain low CO<sub>2</sub>-concentration-levels indoors, the increase of outdoor air intake is associated with a more or less important introduction of outdoor air pollutants in the building. Among these pollutants, there are particulate pollutants as PM<sub>2.5</sub> and there is NO<sub>2</sub> that is a gaseous pollutant mainly emitted by the road-traffic. Many previous papers dealt with the indoor/outdoor dynamics. However, only rare studies, like Bucur et Danet (2019), Bi et al. (2021) or Nezis et al. (2022), were based on outdoor air measurements up to 500 m away from the studied buildings.

The aim of this study is to evaluate such dynamics for PM<sub>2.5</sub> and NO<sub>2</sub>. It was based on a two-months measurements campaign in three buildings presenting different ventilation types. In addition to the reference data of the local air quality monitoring station, an optical particles measurement was introduced on the façade of the buildings.

#### 2 METHODS AND MATERIAL

#### 2.1 Site description

For this study, three public buildings with different ventilation conditions were chosen within a 300 m of an ambient air quality monitoring station. The environment is an urban busy traffic. A short description of the characteristics of these buildings is given in *Table 1Erreur! Source du renvoi introuvable*..

### 2.2 Sampling methods

Different sensors were used for the campaign to measure the concentrations of particulate matter with an equivalent diameter less than 2.5  $\mu g.m^{-3}$  (PM<sub>2.5</sub>), black carbon (BC), nitrogen oxides (NOx, NO<sub>2</sub>, NO). Indoors, there was at least one monitor or sensor for each kind of measurement. And there was one PM<sub>2.5</sub> sensor on the air intake façade of each building, that also provides air pressure. The technology to measure the particle matter is optical particle

counter. A low-cost monitor is used here, that also delivers measurements of CO<sub>2</sub>, temperature and relative humidity inside. NOx measurement has been possible in one of the buildings only, using a chemiluminescence-based analyser. The technology used to measure the black carbon is an aethalometer. And Atmo AuRA, the air pollution surveillance actor for the region, delivered data from the nearby station. *Table 2* gives details on the used material in the buildings and on their façades. Prior to the campaign, the eight AirVisual sensors were put under inter-comparison for three months in the laboratory. The installation of PM<sub>2.5</sub> measurements devices for each building of the campaign was then based on the AirVisual technology version and on the results on the coefficient of determination, as shown in *Table 3*.

Table 1: Main characteristics of the buildings included in the measurements campaign

Building	Floors number	Façade measurement (campaign)	Year of construction	Refurbish ment	Ventilation type
School	4	West	1960's	Upcoming	No system, manual airing (windows)
Event center	2	West	1990's	Upcoming	Balanced ventilation (activated when an event is scheduled)
Library	6	East	1990's	No	HVAC system with filters. Turned off at night and on Sundays

Table 2: Main characteristics of the sampling material for the measurements campaign

	Elass (NI)	NIL of	Brand	of monitor/sensor	Building facade	
Building	Floor (Nb of rooms)	Nb of monitors	PM <sub>2.5</sub> , CO <sub>2</sub> , Temp, RH	ВС	NOx	PM <sub>2.5</sub>
School	3 <sup>rd</sup> floor (2)	2	AirVisual NODE (IQAir)	AE31 (Magee Scientific)	ENVEA analyser (Atmo AuRA)	AirVisual Outdoor (IQAir)
Event center	Staircase (1)	1	AirVisual PRO (IQAir)	MA300 (Aethlabs)	-	AirVisual Outdoor (IQAir)
Library	2 <sup>d</sup> and 3 <sup>rd</sup> floors (2)	2	AirVisual PRO (IQAir)	MA300 (Aethlabs)	-	AirVisual Outdoor (IQAir)

Table 3: AirVisual Indoor and Outdoor inter-comparison results (R2)

AirVisual Indoor device(s)	Indoor/Indoor R <sup>2</sup>	Indoor /Outdoor R <sup>2</sup>	Building destination into the campaign
Pair of NODE	0.984	0.983 a	School
Pair of PRO	0.986	0.981 a	Library
Remaining PRO	-	0.966	Event Center

a: This determination coefficient is the average of the determination coefficients of the Outdoor device with each Indoor monitor of the Indoor pair.

# 2.3 Data Analysis method

The campaign was carried out from January 11<sup>th</sup> to March 7<sup>th</sup>, 2024. After collecting the data from the monitors and analysers, a cleaning step was performed, mainly to keep out the

temporal discrepancies from the outputs of the AirVisual devices. The cleaned data were then averaged into different time-step levels with the R package openair (Carslaw et al., 2011), i) to match the time step of the data provided by the ambient air quality monitoring station (15 minutes), ii) to determine the European Air Quality Index, EAQI, of the concentrations from the station (respectively 1 hour and 1-day-time steps for NO<sub>2</sub> and PM<sub>2.5</sub>). As the black carbon data treatment is not yet finished, the present summary only covers the PM<sub>2.5</sub> and NOx analysis. The data were analysed to get a knowledge of the outdoor-indoor air pollution dynamics: i) at the campaign' scale, and ii) at specific high pollution periods within the campaign. The global study involves several approaches and parameters such as a statistical approach of the distribution of the measurements, the occupation' definition through surveys, etc. Here, the summary presents the results on a daily profile approach, with the 15-minutes I/O ratio of PM<sub>2.5</sub> and NO<sub>2</sub> concentrations.

#### 3 RESULTS

### 3.1 Indoor/outdoor dynamics of NO<sub>2</sub>

During the campaign, the outdoor  $NO_2$  concentration never exceeded 90  $\mu$ g.m<sup>-3</sup> per hour, the EAQI upper limit for the Fair class. Indeed, the  $NO_2$  1-hour-step outdoor concentration stayed within the interval of 0.7 to 73.5  $\mu$ g.m<sup>-3</sup>. In the daily-profiled concentrations presented in *Figure 1.a*), we can observe two peaks in the outdoor concentration, one in the morning and the other at the end of the day, corresponding to the peaks of traffic in urban areas. The indoor concentration curve is rather flat, and the maximum I/O ratio of 0.70 was found at mid-day.

### 3.2 Indoor/outdoor dynamics of PM<sub>2.5</sub>

We plotted the PM<sub>2.5</sub> concentration indoors and outdoors and the I/O ratios for the school, the event center and the library within a daily profile, on a 15-minutes time-step level (*Figure 1.b to d*). Two days in January and two in February, we observed at the station that the outdoor PM<sub>2.5</sub> concentration did go beyond the value of 25 µg.m<sup>-3</sup> per day, the upper limit of the Moderate class of the European Air Quality Index. In *Table 4* are presented the minimum and maximum I/O ratios representing the indoor averaged concentrations over the station outdoor concentrations during the campaign period. It also gives the detail of the median I/O ratio values in and out of the four dates where the daily concentration is above 25 µg.m<sup>-3</sup>. It is noteworthy that, according to the occupation's survey, a window was opened in one of the two monitored rooms of the school at 1.00 PM UTC, on date no. 3, and that no event was mentioned on any of these dates in the monitored room of the event center. There, the ventilation was then off. In the school, the maximum I/O ratio of 5.49 corresponded to a reported combustion activity in one of the classrooms, in the beginning of March.

Table 4: 15-minutes-averaged	aanaantration	I/O rotio	of DM2 5 da	wing the com	naian namiad	(11 a m-3)
Table 4: 15-minutes-averaged	concentration	1/ <b>U</b> ramo	OT PIVIZ.3 at	iring the cam	naign neriod	(ug.m <sup>-</sup> )

Building	Days where daily concentration is under 25 μg.m <sup>-3</sup>			Dates where daily concentration is above 25 μg.m <sup>-3</sup>			
	Min.	Max.	Median	Min.	Max.	Median	
School a	0.00	5.49	0.34	0.12	0.59	0.29	
Event center b	0.00	5.35	0.54	0.39	0.85	0.59	
Library <sup>a</sup>	0.00	2.05	0.12	0.04	0.33	0.13	

a: Indoor concentration as the average of the values of two sensors.

b: Indoor concentration as the value of one sensor.




Figure 1:15-minutes-averaged concentration in a daily profile of the campaign period

#### 4 DISCUSSION

Considering the daily profile of I/O ratios, having the inside measured concentration above the outside measured concentration never happens for both pollutants. In the case of PM<sub>2.5</sub>, early morning corresponds to the library' highest I/O ratio, when the ventilation is turned on back for the day. Otherwise, the indoor concentration of the library stays far below the outside one during the day. That can be due to the performance of filters. For both pollutants, the peak of I/O ratio for the school is at mid-day, and a weaker one occurs after midnight in the case of NO<sub>2</sub>. No clear pattern comes out of the daily profile of the event center, which could be due to an activation of ventilation only when a meeting takes place in the monitored room (seven events reported on seven different dates, four during the day and three at the end of the day or at night). The same can be said of the library, and in this case, it might be due to a random presence of visitors and rooms with a larger volume, but there are two peaks, one in the morning and a wider one in the afternoon. Except for the library, the daily profiles let us guess a transfer of the pollution from the outside to the inside, especially in the case of the event center. Time series give a better indication of potential delays of the transfer, and further analysis will allow an accurate determination. To enhance the knowledge of the air pollution transfer in the building, the impact of different parameters should be further investigated. For example, measurements in situ, including air flows of the ventilation systems will be used to characterize the ventilation parameters. The CO<sub>2</sub> concentration decay method could be implemented, like Persily did (Persily, 1997), to determine Air Change Rate (ACR) in the rooms, specifically for the school and its manual airing.

# 5 CONCLUSION & PERSPECTIVES

The monitored rooms in these three different buildings present specific indoor air pollution temporal evolution, and we observe that the less polluted building is the library (mechanically ventilated with filters), followed by the event center (mechanically ventilated when occupied only) and at last, by the school (manual ventilation). On a daily profile point of view, both NO<sub>2</sub> and PM<sub>2.5</sub> I/O ratios never exceed the value of 1, but they can be close to it, when considering the school. Looking specifically at the median I/O ratio, higher outdoor pollution seems to rise the PM<sub>2.5</sub> transfer to the buildings, except for the school, which shows in this study the limit of that indicator and/or which indicates that the data quality step needs to be strengthened if working with I/O ratios. As for NO<sub>2</sub>, we found out a daily-profiled I/O ratio under the value of 1 and an hourly-concentration below the EAQI' Fair class upper limit.

As for the experiment method, a configuration where PM<sub>2.5</sub> sensors are installed on the façade, as near as possible of the air intake, led to similar measurements between the three buildings, that are in the same neighbourhood. Nonetheless, an even greater remarkable point is that the three measurements seem to be well correlated with the ambient air quality monitoring station in their surroundings, excepting when the outside PM<sub>2.5</sub> pollution rises in a peak.

Thus, this study brings important information for a global comprehensive understanding of the dynamics of outdoor/façade/ indoor concentrations of particulate matter (PM<sub>2.5</sub>) and gaseous pollution (NO<sub>2</sub>), because data were produced from different monitored buildings/ventilation systems. A second step in this work will be to characterize the transfer into the buildings, comparing the following results from both points of view of the façades and the station: amount of concentration, time delay. And if possible, the health impact of this transfer will be determined. We will analyse an additional pollutant, measured in each building, that is black carbon, particularly specific to outdoor emissions. A third step will be to conduct a second measurements campaign, in three other public buildings and in the same region. Finally, the results of the experimental phasis will be used in air pollution and aeraulic modelling programs to further investigate the question of the transfer control and its parameters.

#### 6 ACKNOWLEDGEMENTS

This work was founded by the French Agency For Ecological Transition (ADEME) within the AQACIA program (project no.: 2204D0048). All of the authors would like to thank Atmo Auvergne Rhône-Alpes, the local air pollution surveillance actor, for providing data, material and support. The Grand Chambéry and the Département of Savoie, local territorial actors, for support and making public buildings available.

# 7 REFERENCES

Bi et al. (2021). Characterizing Outdoor Infiltration and Indoor Contribution of PM2.5 with Citizen-Based Low-Cost Monitoring Data. *Environmental Pollution* 276 (May 2021): 116763. https://doi.org/10.1016/j.envpol.2021.116763.

Bucur et Danet (2019). Indoor/outdoor correlations regarding indoor air pollution with particulate matter. *Environmental Engineering and Management Journal* 18, no. 2 (February 2019): 425-32.

Carslaw, David C., and Karl Ropkins. (2012). Openair An R Package for Air Quality Data Analysis. *Environmental Modelling & Software* 27–28: 52–61. https://doi.org/10.1016/j.envsoft.2011.09.008. European Environment Agency, *About the European Air Quality Index* <a href="https://www.eea.europa.eu/themes/air/air-quality-index">https://www.eea.europa.eu/themes/air/air-quality-index</a>

Nezis et al. (2022). Linking Indoor Particulate Matter and Black Carbon with Sick Building Syndrome Symptoms in a Public Office Building. *Atmospheric Pollution Research* 13, no. 1 (January 2022): 101292. <a href="https://doi.org/10.1016/j.apr.2021.101292">https://doi.org/10.1016/j.apr.2021.101292</a>.

Persily. (1997). Evaluating Building IAQ and Ventilation with Indoor Carbon Dioxide. <a href="https://www.aivc.org/resource/evaluating-building-iaq-and-ventilation-indoor-carbon-dioxide">https://www.aivc.org/resource/evaluating-building-iaq-and-ventilation-indoor-carbon-dioxide</a>